MARCHINGTONSTONE

TYPICAL GRADING ANALYSIS

CUSTOMER:	Enviromesh
CONTACT:	James Self

MATERIAL	75/150mm Limestone
PRODUCT CODE	150-75/LS Graded Aggregate 6G
SPECIFICATION	SHW Series 600

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
500	100	100	40	0	
150	100		31.5	0	
125	93	10-95	25	0	
100	42		4	0	
75	4		1	0	
63	2		0.600	0	0-25
50	1		0.063	0	

REMARKS:

Sample complies with the grading requirements

As received moisture content = 1.6%

Date: 08/02/2026

105 Buxton Road, High Lane, Stockport, SK6 8DX
T: 01663 765000 Fax: 01663 763777 www.marchingtonstone.co.uk