

I. Phillips

CERTIFICATE OF TEST PHYSICAL AND MECHANICAL PROPERTIES

CERTIFICATE No:	27131	DATE OF TEST:	11/11/25	DATE OF ISSUE:	19/11/25
Material	6/14 Limestone ex CEMEX UK Materials Limited – Dove Holes				
Aggregate Size Fraction	As Received				
Originator	I. Phillips – CEMEX UK Materials Limited				
Lab Reference No.	3454				
Certificate of Sampling No.	511				
Date Received	20/10/25				
Date Sampled	17/10/25				

TEST REQUESTED	TEST RESULTS		TEST METHOD
1. Particle Density (Mg/m ³)	1. a) Saturated Surface Dry	2.71	1. BS EN 1097-6: 2022 Cl. 8
	b) Oven Dry	2.71	
	c) Apparent	2.72	
2. Water Absorption (%)	2.	0.1	2. BS EN 1097-6: 2022 Cl. 8
3. Loose Bulk Density (Mg/m ³)	3. Individual Result	Mean	3. BS EN 1097-3: 1998
	a)	1.332	
	b)	1.349	1.34
	c)	1.342	
4. Resistance to Fragmentation (LA Method) *	4.	24	4. BS EN 1097-2: 2020

* Test Portions obtained using 14.0mm, 12.5mm and 10mm Test Sieves According to BS EN 1097 Part 2

Results apply to the sample as received.

Report checked and approved by:



W Elson - Laboratory Manager